

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:17 pm

PWS ID: UTAH17024 **Name:** EDGE OF EDEN SUBDIVISION

Legal Contact: EDGE OF EDEN SUBDIVISION **Rating:** Approved
MAX SAVAGE **Rating Date:** 04/09/1996

Address: 728 WEST 200 SOUTH **Activity Status:** Active
SALT LAKE CITY, UT 84104

Phone Number: 435-359-8635

City Served (Area):

County: RICH COUNTY

System Type: Non-community **Last Inv Update:** 06/09/2009 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 08/28/2009 **Total Dsgn Cap:**
Population: 25 **Surveyor:** DAVID F HANSEN **Total Emerg Cap:**
Oper Period: 4/1 to 9/30

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers	Emergency	Email Address
AC	SAVAGE, MAX		801-274-2412		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unknown	0	15
			15 Total Svc Connections

Storage

Total Storage: 43,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	43,000 GAL			A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	SUBDIVISION WELL	Active	WL	6	55 GPM	27 GPM	Yes	GW	Seasonal	4/1 to 9/30	

**Reports measured flow for wells, approved design capacity for all other sources.*